

## ADDENDUM 001 Request for Bid Drake Maintenance Facility Septic System Improvements Project RFB 9-160414KH

Bidders should acknowledge receipt of Addendum 001 (ONE) by signing and including it with the original bid. The due date for receipt of bids **has not** changed by this Addendum; the due date is **April 14, 2016 2:00 PM Central Time**. Accordingly, the following clarifications, and or additional information, are believed to be of general interest to all potential bidders. All other terms and conditions remain unchanged and in full force.

Name and Title of Signer (Print or type)	Name and Title of Department Authority  Kristi Hixson General Services Senior Specialist
Contractor/Offeror Signature   (Signature of person authorized to sign)	Department of Transportation  <i>Kristi Hixson</i>  (Authorizing Signature)
Date Signed:	Date Signed: 4/7/2016

### Plan Sheet Revisions/Clarifications:

- Sheet 1** A check valve on the dispersal system supply line was deleted.
- Sheet 1** The flush valve on the return line shall be automatic, controlled by the drip system controls. Connect the return line to the primary tank.
- Sheet 1** Septic System Site Plan. Added the locations to connect to the existing electrical panel on the Cold Storage Building and placing the new control panel on the Maintenance Building.
- Sheet 2** All access lids for the primary tank, aeration tank and dosing tank shall be cast iron.



- Sheet 2**      Aeration Tank Note 1: 1500 Series Media Plant by Jet, Inc. is an approved equal for the aeration tank. If a pretreatment tank is integral to the aeration treatment tank system, an additional primary tank is not necessary. However, the system must still have the capacity to retain at least 48 hours' flow.
- Sheet 2**      Note 1: This note has been changed to reflect that the silt loam fill shall be as defined by the USDA's Natural Resource Conservation Service's Soil Texture Classification.
- Sheet 2**      Note 15: The abandoned septic tank shall be filled with sand or clean gravel.
- Sheet 2**      Note 16: This note was modified to explain the electrical connections shown on Sheet 1.
- Sheet 2**      Note 17: The various appurtenances of the onsite system listed shall be marked. Markers must be green and placed a minimum of 24 inches below grade. See location marker detail on Sheet 2.

## **REVISED DRAWINGS – SEPARATE ATTACHMENT**

### **Additional Information/Clarifications:**

Prevailing Wage Rates for Building Construction shall be used for this project.

Utilities owned by MoDOT on the maintenance facility site will be marked by MoDOT. A list of the utilities will be provided to the awarded contractor.

MoDOT will remove the brush pile on site prior to construction.

MoDOT will determine where spoils shall be placed on property.