

Missouri Department of Transportation

1590 Woodlake Drive
Chesterfield, Missouri 63017-5712
314.275.1500
Fax: 573.522.6475
1.888.ASK MODOT (275.6636)

ADDENDUM 00 REQUEST FOR BID SL16-031-RW Line Bore

Bidders shall acknowledge receipt of Addendum 002 (TWO) by signing and including it with original bid. The due date for receipt of this bid **does not change** by this Addendum. Accordingly, the following clarifications, additions/deletions, questions and answers are believed to be of general interest to all potential bidders. All other terms and conditions remain unchanged and in full force.

Name and Title of Signer (Print or type)	Name and Title of Department Authority Teresa (Terri) Mount Sr. Procurement Agent
Bidder Signature	Department of Transportation <u>Authorizing Signature</u>
<u>Signature of person authorized to sign</u>	<i>Terri Mount</i>
Date Signed:	Date Signed: October 19, 2015

QUESTION:

The addendum shows a pull rope in the conduit, but the original description states we should use Cable in Conduit after the bore to enter the light pole. Are we supposed to get the conduit bored in and MoDot personell will install the Cable in Conduit and terminate the wiring at both ends? OR will we complete all of this work?

MODOT RESPONSE:

The winning bidder is just installing the conduit run with pull rope inside.

THIS PAGE MUST BE SIGNED AND RETURNED WITH ORIGINAL RFB.



Our mission is to provide a world-class transportation experience that delights our customers and promotes a prosperous Missouri.

www.modot.org