

Missouri Department of Transportation
Roberta Broeker, Interim Director

573.751.2551
Fax: 573.751.6555
1.888.ASK MODOT (275.6636)

ADDENDUM 002 Request for Bid King City Maintenance Building RFB 9-150708KH

Bidders should acknowledge receipt of Addendum 002 (TWO) by signing and including it with the original bid. The due date for receipt of bids **has not** changed by this Addendum; the due date is **July 8, 2015 2:00 PM Central Time**. Accordingly, the following clarifications, and or additional information, are believed to be of general interest to all potential bidders. All other terms and conditions remain unchanged and in full force.

Name and Title of Signer (Print or type)	Name and Title of Department Authority Kristi Hixson General Services Senior Specialist
Contractor/Offeror Signature (Signature of person authorized to sign)	Department of Transportation <i>Kristi Hixson</i> (Authorizing Signature)
Date Signed:	Date Signed: 7/1/2015

Drawing Page 2 of 28, Site Note E includes an Add Alternate for a concrete slab. A Revised Bid Form page is included with this addendum that includes the Add Alternate.

Remove Sheet 14 and 15 (Head & Jamb Details) and insert new Sheet 14 and 15 (included as separate attachment).

In lieu of 26 gauge roofing panels with single bubble insulation, the contractor may use Central States (or equal) 26 gauge pre-finished metal panels under the brand name of DripX Condensation Control.

Clarification:

Concrete cylinders by the contractor are to be submitted to MoDOT for breaking and testing.

Any horizontal abutments of the FRP shall have installed pre-finished aluminum drip trim in the joints.



Contractor shall install pre-finished metal rat guard with foam closure strip matching wall panel profile.

Question: Since this is a MoDOT project do local building permits need to be pulled as well as plumbing and electrical?

Answer: As stated in the Special Terms and Conditions:

Permits, Licenses and Safety Issues

The contract price shall include any necessary permits and licenses required by law incidental to the work. Local ordinances requiring building permits are not applicable to state agencies.

00301

REVISED BID FORM

To: The Missouri Highway and Transportation Commission
PO Box 270
Jefferson City, Missouri 65102

1. The undersigned, having examined the proposed Contract Documents titled: **9-150708KH – King City Maintenance Building** and having visited the site and examined the conditions affecting the work, hereby proposes and agrees to furnish all labor, materials, equipment and everything which may be necessary or incidental thereto, as proposed by said Contract Documents, all to the satisfaction of the General Services-Facility Operations Supervisor or designated representative of the Missouri Department of Transportation and the Missouri Highway and Transportation Commission, for the stipulated sum of:

BASE BID _____ DOLLARS

(\$ _____)

ALTERNATE BID _____ DOLLARS

(CONCRETE SLAB)

(\$ _____)

Note: The ALTERNATE BID is a separate dollar amount and is not included in the base bid. Award will be based on the Base Bid only. Vendors are not required to bid the Alternate Bid.

2. The undersigned, acknowledges having examined and being familiar with the contract documents including the drawings, the Instructions to Bidders, General Conditions, Supplementary Conditions and the body of technical specifications.
3. The undersigned acknowledges receipt of Addenda number _____ through _____ inclusive.
4. Enclosed with this bid is bid security in the amount of not less than 5% of the bidder's proposed Contract Sum (Base Bid + Alternate), the amount being

_____ DOLLARS

(\$ _____).

IF AN INDIVIDUAL

Name of individual

Residence address

Social Security Number

Telephone Number

Firm Name, If Any

Address for communications

Signature