

## ADDENDUM 001 Request for Bid Rolla and Steelville Truck Wash Door Addition RFB 9-160209KH

Bidders should acknowledge receipt of Addendum 001 (ONE) by signing and including it with the original bid. The due date for receipt of bids **has** changed by this Addendum; the due date is **February 17, 2016 2:00 PM Central Time**. Accordingly, the following clarifications, and or additional information, are believed to be of general interest to all potential bidders. All other terms and conditions remain unchanged and in full force.

Name and Title of Signer (Print or type)	Name and Title of Department Authority  Kristi Hixson General Services Senior Specialist
Contractor/Offeror Signature   (Signature of person authorized to sign)	Department of Transportation  <i>Kristi Hixson</i>  (Authorizing Signature)
Date Signed:	Date Signed: 2/8/2016

### Plan Sheet:

**Steelville Sheet 5** Indicates there is insulation above the ceiling liner panel. Clarification: Contractor shall install R36 blown in fiberglass insulation above existing ceiling and one, 24"x24" scuttle whole access with metal trim.

**Rolla Sheet 5** Indicates there is insulation above the ceiling liner panel. Clarification: Contractor shall install R36 blown in fiberglass insulation above existing ceiling and one, 24"x24" scuttle whole access with metal trim.

