



Ed Hassinger, District Engineer

---

**ADDENDUM 001  
REQUEST FOR BID  
SL14-002-RW Pipe Replacement**

Bidders shall acknowledge receipt of Addendum 002 (TWO) by signing and including it with original bid. The due date for receipt of this bid **does not change** by this Addendum. Accordingly, the following clarifications, additions/deletions, questions and answers are believed to be of general interest to all potential bidders. All other terms and conditions remain unchanged and in full force.

Name and Title of Signer (Print or type)	Name and Title of Department Authority  Teresa (Terri) Mount Sr. Procurement Agent
Bidder Signature/Company	Department of Transportation  <i>Terri Mount</i>
<div>Signature of person authorized to sign</div>	<div>Authorizing Signature</div>
Date Signed:	Date Signed: June 26, 2013

**THIS PAGE MUST BE SIGNED AND RETURNED WITH ORIGINAL RFQ.**

*Can you confirm that MoDOT will supply traffic control & the geotextile fabric. Yes, MoDOT will supply the traffic control and geotextile fabric.*

*Is this existing 30" VCP Pipe connected to the existing drop inlet that is to be replaced. No. The existing 30" VCP is much deeper than the drop inlet. Only a 12" pipe is connected to the drop inlet.*