

Missouri Department of Transportation
David B. Nichols, Director

573.751.2551
Fax: 573.751.6555
1.888.ASK MODOT (275.6636)

ADDENDUM 003 Request for Bid King City Sewer Improvements Project RFB 9-150313KH

Bidders should acknowledge receipt of Addendum 003 (THREE) by signing and including it with the original bid. In addendum 002, the due date for receipt of bids was extended to **March 27, 2015 2:00 PM Local Time**. Accordingly, the following clarifications, and or additional information, are believed to be of general interest to all potential bidders. All other terms and conditions remain unchanged and in full force.

Name and Title of Signer (Print or type)	Name and Title of Department Authority Kristi Hixson General Services Senior Specialist
Contractor/Offeror Signature (Signature of person authorized to sign)	Department of Transportation <i>Kristi Hixson</i> (Authorizing Signature)
Date Signed:	Date Signed: 03/23/2015

PLAN SHEETS

- Attached are revised plans sheets E-1, E-2, E-3 and E-4. The revisions are noted by revision clouds and designated "1".
- A flow meter is not required on the sewer forcemain. Plans Sheets C1, C4, and C6 have been revised to remove the flow meter and meter pit from the sewer forcemain. References to the flow meter on the sewer forcemain in the electrical Plans Sheets E-1, E-2, E-3 or E-4 and within the project specifications can be ignored.



Our mission is to provide a world-class transportation experience that delights our customers and promotes a prosperous Missouri.

www.modot.org