

Missouri Department of Transportation  
Roberta Broeker, Interim Director

573.751.2551  
Fax: 573.751.6555  
1.888.ASK MODOT (275.6636)

## ADDENDUM 003 Request for Bid Williamsburg Septic System Improvements Project RFB 9-150602KH

Bidders should acknowledge receipt of Addendum 003 (THREE) by signing and including it with the original bid. The due date for receipt of bids **has** changed by this Addendum; the due date is **June 5, 2015 2:00 PM Central Time**. Accordingly, the following clarifications, and or additional information, are believed to be of general interest to all potential bidders. All other terms and conditions remain unchanged and in full force.

Name and Title of Signer (Print or type)	Name and Title of Department Authority  Kristi Hixson General Services Senior Specialist
Contractor/Offeror Signature  (Signature of person authorized to sign)	Department of Transportation  <i>Kristi Hixson</i> (Authorizing Signature)
Date Signed:	Date Signed: 6/1/2015

### Plan Clarifications:

- The design soil loading rate for the proposed mound system should be 0.4 gallons per day, per square foot (gpd/SF), per the Williamsburg soils report. Revise the 0.05 gpd/SF to 0.4 gpd/SF. The sand mound design was based on the 0.4 gpd/SF. The sand mound is to be built up so that base of the gravel pad is 16 inches above the existing ground surface, which will maintain a minimum 24 inches above the seasonally high groundwater table.
- A layer of topsoil is to cover the entire mound at a minimum thickness of six (6) inches, and should be landscaped as necessary. Installation of the system is to be done according to the system manufacturer.

