


Missouri Department of Transportation
*David B. Nichols, Director*573.751.2551
Fax: 573.751.6555
1.888.ASK MODOT (275.6636)**ADDENDUM 002**
KCDC Maintenance Services Project
Request for Bid 9-130927TV

Bidders should acknowledge receipt of Addendum 002 (TWO) by **signing** and **including it** with the original bid. The due date for receipt of bids remains **unchanged** by this Addendum. Accordingly, the following clarifications, questions and answers are believed to be of general interest to all potential bidders. All other terms and conditions remain unchanged and in full force.

Name and Title of Signer (Print or type)	Name and Title of Department Authority Name: Tom Veasman Title: Sr. General Services Specialist
Contractor/Bidder Signature (Signature of person authorized to sign)	Department of Transportation  (Authorizing Signature)
Date Signed:	Date Signed: September 24, 2013

VENDOR QUESTIONS & GENERAL CLARIFICATIONS:

The attached sheet provides serial numbers for cooling/UPS equipment located in the Kansas City Data Center. This information may be useful to vendors in determining pricing information for this Request for Bid.



Addendum 002 Attachment

Type	Status	Model	Hostname	Parent Device	Mai...	Serial Number	IP Address	Location
 Cooling Device	Normal	InRow RC	192.168.1.55	KC_ISX (StruxureWare Central)	No	UK0939111158	192.168.1.55	IRC Row C Rack 5
 Cooling Device	Normal	InRow RC	192.168.1.74	KC_ISX (StruxureWare Central)	No	UK1010211331	192.168.1.74	IRC Row D Rack 9
 Cooling Device	Normal	InRow RC	192.168.1.58	KC_ISX (StruxureWare Central)	No	UK0939111167	192.168.1.58	IRC Row A Rack 3
 NetBotz Rack Appliance	Normal	NetBotz Rack Monitor 550	192.168.1.62	192.168.1.62	No	5A0840V00057	192.168.1.62	Row A Rack 13
 Cooling Device	Normal	InRoom Chilled Water	192.168.1.64	KC_ISX (StruxureWare Central)	No	5A0913V00940	192.168.1.64	
 Cooling Device	Normal	InRow RC	192.168.1.50	KC_ISX (StruxureWare Central)	No	UK0939111161	192.168.1.50	IRC Row B Rack 4
 Cooling Device	Normal	InRow RC	192.168.1.59	KC_ISX (StruxureWare Central)	No	UK0939111144	192.168.1.59	IRC Row B Rack 2
 Cooling Device	Normal	InRoom Chilled Water	192.168.1.63	KC_ISX (StruxureWare Central)	No	5A0913V00939	192.168.1.63	
 PDU	Normal	InfraStruXure Modular PDU	192.168.1.44	KC_ISX (StruxureWare Central)	No	PD0929130855	192.168.1.44	MPDU Row D Rack 1
 PDU	Normal	InfraStruXure Modular PDU	192.168.1.76	KC_ISX (StruxureWare Central)	No	PD0931130045	192.168.1.76	MPDU Row C Rack 1
 Cooling Device	Normal	InRow RC	192.168.1.70	KC_ISX (StruxureWare Central)	No	UK1010211388	192.168.1.70	IRC Row D Rack 4
 NetBotz Rack Appliance	Normal	NetBotz Rack Monitor 550	192.168.1.66	192.168.1.66	No	QA0948181320	192.168.1.66	Row D Rack 2
 Cooling Device	Normal	InRow RC	192.168.1.51	KC_ISX (StruxureWare Central)	No	UK0939111172	192.168.1.51	IRC Row B Rack 7
 NetBotz Rack Appliance	Normal	NetBotz Rack Monitor 550	192.168.1.41	192.168.1.41	No	5A0841V00209	192.168.1.41	NB550 Row C Rack 6
 Cooling Device	Normal	InRow RC	192.168.1.54	KC_ISX (StruxureWare Central)	No	UK0939111168	192.168.1.54	IRC Row C Rack 8
 PDU	Normal	InfraStruXure Modular PDU	192.168.1.47	KC_ISX (StruxureWare Central)	No	PD0929130835	192.168.1.47	MPDU Row E Rack 13
 Cooling Device	Normal	InRow RC	192.168.1.49	KC_ISX (StruxureWare Central)	No	UK0939111174	192.168.1.49	IRC Row A Rack 6
 UPS	Normal	Symmetra PX 500	192.168.1.48	KC_ISX (StruxureWare Central)	No	QD0942140346	192.168.1.48	UPS Room
 Cooling Device	Normal	InRow RC	192.168.1.53	KC_ISX (StruxureWare Central)	No	UK0931110029	192.168.1.53	IRC Row C Rack 10
 NetBotz Rack Appliance	Critical	NetBotz Rack Monitor 550	192.168.1.42	192.168.1.42	No	5A0840V00039	192.168.1.42	Row B Rack 5
 Cooling Device	Normal	InRow RC	192.168.1.61	KC_ISX (StruxureWare Central)	No	UK0939111173	192.168.1.61	IRC Row A Rack 12
 Cooling Device	Normal	InRow RC	192.168.1.69	KC_ISX (StruxureWare Central)	No	UK1012213151	192.168.1.69	IRC Row D Rack 2
 Cooling Device	Normal	InRow RC	192.168.1.73	KC_ISX (StruxureWare Central)	No	UK1003111629	192.168.1.73	IRC Row D Rack 7
 NetBotz Rack Appliance	Normal	NetBotz Rack Monitor 550	192.168.1.65	192.168.1.65	No	QA0948181437	192.168.1.65	Row E Rack 10
 Cooling Device	Normal	InRow RC	192.168.1.52	KC_ISX (StruxureWare Central)	No	UK0939111170	192.168.1.52	IRC Row B Rack 9
 Cooling Device	Normal	InRow RC	192.168.1.60	KC_ISX (StruxureWare Central)	No	UK0939111165	192.168.1.60	IRC Row A Rack 9
 Cooling Device	Normal	InRow RC	192.168.1.56	KC_ISX (StruxureWare Central)	No	UK0939111150	192.168.1.56	IRC Row C Rack 3
 PDU	Normal	InfraStruXure Modular PDU	192.168.1.45	KC_ISX (StruxureWare Central)	No	PD0929130862	192.168.1.45	MPDU Row A Rack 1