


**Missouri Department of Transportation**  
*David B. Nichols, Director*

573.751.2551  
Fax: 573.751.6555  
1.888.ASK MODOT (275.6636)

**ADDENDUM 005  
KC District Pole Barns  
Request for Bid 9-131122TV**

Bidders should acknowledge receipt of Addendum 005 (FIVE) by **signing** and **including it** with the original bid. The due date for receipt of bids remains **unchanged** by this Addendum. Accordingly, the following clarifications, questions and answers are believed to be of general interest to all potential bidders. All other terms and conditions remain unchanged and in full force.

Name and Title of Signer (Print or type)	Name and Title of Department Authority  Name: Tom Veasman Title: Sr. General Services Specialist
Bidder Signature	Department of Transportation  
(Signature of person authorized to sign)	(Authorizing Signature)
Date Signed:	Date Signed: November 19, 2013

**Vendor Question:**

Please clarify the truss load for the Platte City and KC Skiles pole barns.

The specs say live load of 15 PSF and dead load of 5 PSF.

The stamp on drawings shows live load of 20 PSF and dead load of 20PSF.

**Answer:**

The following truss loads shall be used in lieu of the specifications/drawings:

Roof Live Load            20 PSF

Roof Dead Load           4PSF

Bottom Cord Dead Load 5PSF

Earthquake                Zone 1, Latest Edition IBC

Wind                        90 MPH, Exposure B

Deflection                 L/360



*Our mission is to provide a world-class transportation experience that  
delights our customers and promotes a prosperous Missouri.*

[www.modot.org](http://www.modot.org)