



September 25, 2015

Kevin Griep, General Services Specialist  
MoDOT Headquarters  
General Office  
P.O. Box 270  
Jefferson City, MO 64102

Re: **Nashua MoDOT Maintenance Facility, Kansas City, MO**  
**Sanitary Sewer Connection**

Dear Kevin,

This letter is to inform you the Kansas City Missouri Water Services Department (WSD) has no objection with the connection of a 2-inch pressure system to be constructed in accordance with the plans submitted by Shafer Kline and Warren (SKW) on 9/22/2015. The 2-inch pressure system will serve the Nashua MoDOT Maintenance Facility located near NE Cookingham Drive and I-435, in Kansas City, Missouri. The 2-inch pressure system is to be connected the KCMO Manhole BS-04 per the attached First Creek Interceptor Sewer Bristol South Branch plans Sheet BS3.2 and BN2.1. The connection shall be 2 feet above the manhole invert and the hole shall be cored. Please contact sewer line maintenance at 816-513-4810 in advance for the inspection of the connection.

If you have any questions or concerns regarding this project, please feel free to give me a call.

Sincerely,

A handwritten signature in black ink that reads "Julie Jenson".

Julie Jenson, P.E., Project Manager  
Water Services Department  
4800 E. 63<sup>rd</sup> St.  
Kansas City, MO 64130  
816-513-0446