


**Missouri Department of Transportation**  
*David B. Nichols, Director*

573.751.2551  
Fax: 573.751.6555  
1.888.ASK MODOT (275.6636)

**ADDENDUM 005  
NW District Back-up Generator  
Request for Bid 9-150311TV**

Bidders should acknowledge receipt of Addendum 005 (FIVE) by **signing** and **including it** with the original bid. The due date for receipt of bids was extended to **March 18, 2015** at 2:00PM Local Time by Addendum 004. Accordingly, the following clarifications, questions and answers are believed to be of general interest to all potential Bidders. All other terms and conditions remain unchanged and in full force.

Name and Title of Signer (Print or type)	Name and Title of Department Authority  Name: Tom Veasman Title: Sr. General Services Specialist
Bidder Signature	Department of Transportation  
(Signature of person authorized to sign)	(Authorizing Signature)
Date Signed:	Date Signed: March 10, 2015

Q. The existing General Services Building 400amp panel is fed with 4 #500 MCM and the new schedule shows this to be replaced with #600 MCM. Would it be permissible to replace the existing wiring with #500 MCM with ground?

A. #600 Kcmil cable is rated for 420amps. 500 kcmil is rated for 380 amps. 500kcmil wire may be used, but the 400amp switchboard breaker would need to be one with an adjustable trip Long trip setting, and adjusted to 380 amps or less.



*Our mission is to provide a world-class transportation experience that  
delights our customers and promotes a prosperous Missouri.*

[www.modot.org](http://www.modot.org)