

3956 E. Main
Willow Springs, MO 65793
417.469.6256
Fax: 417.469.4449
1.888.ASK MODOT (275.6636)

REQUEST FOR QUOTE
Above Ground 4000 Gallon Fuel Tank
RFQ # SEW14-1696RY

Name and Title of Signer (Print or type)	Name and Title of Department Authority Gloria Bunch Southeast Procurement
Bidder/Offeror Signature <hr/>	Department of Transportation <i>Gloria Bunch</i> <hr/>
(Signature of person authorized to sign)	(Authorizing Signature)
Date Signed:	Date Signed: 1/30/14

Each 4,000 gallon fuel tank should be single wall, primed and painted white with a top mount gauge. Tanks must have a 2" updraft vent and a 6" emergency vent and any necessary fittings.

A 2" plug is needed at the top of the tank for fuel to be pulled out of. Tank readers will also go into a 2" fitting. Drain plugs need to be at the bottom of the tank on skid/stand that will keep tank up off of the floor of the containment area. Our crews will plumb the tanks with existing pumps and hoses.

All applicable NFPA codes must apply. One tank is to be labeled for no-lead fuel. The other tank is to be labeled for diesel fuel. Both must be URL 142 labeled.

